

Bid Document/ बिड दस्तावेज़

| Bid Details/बिड विवरण | |
|--|--|
| Bid End Date/Time/बिड बंद होने की तारीख/समय | 04-06-2024 11:00:00 |
| Bid Opening Date/Time/बिड खुलने की तारीख/समय | 04-06-2024 11:30:00 |
| Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से) | 60 (Days) |
| Ministry/State Name/मंत्रालय/राज्य का नाम | Ministry Of Railways |
| Department Name/विभाग का नाम | Indian Railways |
| Organisation Name/संगठन का नाम | Western Railway |
| Office Name/कार्यालय का नाम | Western Railway |
| Total Quantity/कुल मात्रा | 2 |
| Item Category/मद केटेगरी | Online UPS (V2) (Q2) |
| MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट | No |
| Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट | No |
| Document required from seller/विक्रेता से मांगे गए दस्तावेज़ | OEM Authorization Certificate, Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया | No |
| Type of Bid/बिड का प्रकार | Single Packet Bid |
| Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय | 2 Days |
| Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No |
| Evaluation Method/मूल्यांकन पद्धति | Total value wise evaluation |

EMD Detail/ईएमडी विवरण

| | |
|-------------------|----|
| Required/आवश्यकता | No |
|-------------------|----|

ePBG Detail/ईपीबीजी विवरण

| | |
|-------------------|----|
| Required/आवश्यकता | No |
|-------------------|----|

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

| | |
|--|----|
| MII Purchase Preference/एमआईआई खरीद वरीयता | No |
|--|----|

MSE Purchase Preference/एमएसई खरीद वरीयता

| | |
|---|-----|
| MSE Purchase Preference/एमएसई खरीद वरीयता | Yes |
|---|-----|

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

Online UPS (V2) (2 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|---------------|------------------------------------|--|
| Generic | Rating in KVA | 2.0 KVA |
| | Switching Technology | IGBT-PWM |
| | Input Voltage | AC Single phase 160V - 260V 50Hz |

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|---|--|---|
| | Output Voltage | AC Single phase 230V +/-1% 50 Hz |
| | Warranty for UPS (Years) | 5 Or higher |
| Battery/Backup Bank | Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021) | With Battery |
| | Type of Battery (hint: NA in case Battery not provided) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest |
| | Backup time (Minutes) (hint: NA in case battery not provided) | 120 Minutes |
| | Minimum Guaranteed VAH | 1600 X Per KVA X Per hour of backup time |
| | Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided | 2, 3 Or higher |
| Installation and Commissioning or Service | Installation and Commissioning (Covered in the Scope of Supply) | Provided |
| | After sales service (Turn Around Time) | Within 48 hours |
| | Other Services provided | PAN India service support on 24 x 7 basis |
| Performance / Functional | Inbuilt isolation transformer | Without |
| | Overall Efficiency (%) | >=90% & <94% without Inbuilt isolation transformer |
| | Overload limit | 20% Overload for minimum 5 minute, 50% Overload for minimum 3 seconds |
| | Total Harmonic Distortion(THD) (%) | 3% Maximum @ 100% Linear Load |
| | Other Functional Features | Crest factor on full non-linear load is not less than 3:1, Noise level (1 meter distance from UPS) should be less than 70dB |

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|----------------------------|--|--|
| Accessories | Accessories | Rack for Batteries, Cabling 6 meters (input upto 3m and output upto 3m), Paralleling kit (Hot Standby Configuration), Paralleling kit for synchronizing (Parallel Redundant Load Sharing Configuration), SNMP Card (with Suitable Software) for communication, The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc, NA |
| Salient Features | Protection | Protection for under voltage at battery terminal |
| | Metering | Input Voltage, Output Voltage, Input Frequency, Output Frequency |
| | Alarms and Indications | Alarm for Low Battery, Indicator for Mains presence |
| | Additional Features | Pure Sinewave AC Output |
| Design / Construction | Type of Design / Construction | Floor Standing |
| | Enclosure (mm) | 1.0 mm Minimum Thickness of M.S. Sheet duly powder coated |
| | Degree of Protection | IP21, IP20 Or higher |
| | Other Constructional Features | Mains ON/OFF MCB |
| Operating Conditions | Minimum Operating Temperature | 0, -5 Or lower (degree Celsius) |
| | Maximum Operating Temperature | 45, 50 Or higher (degree Celsius) |
| | Relative Humidity Non Condensing at 40 deg C | 90, 95 Or higher (percent) |
| Buyer Specific Requirement | Intended Applications | Critical Infrastructure, Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme |
| | Other Requirements | KW rating shall be 0.8 time of KVA rating |
| Reports And Certification | Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification | OEM |
| | Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand | Yes |
| | As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable | Yes (For UPS rating upto 10KVA) |

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

| S.No./क्र. सं. | Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी | Address/पता | Quantity/मात्रा | Delivery Days/डिलीवरी के दिन |
|----------------|---|---|-----------------|------------------------------|
| 1 | Yagnik Alpesh | 380001,SENIOR SECTION ENGINEER (ELECTRIC) RAC BG OLD YARD COACHING DEPOT NERA GHEE BAZAR KALUPUR AHMEDABAD-380001 | 2 | 90 |

Special terms and conditions-Version:1 effective from 06-07-2022 for category Online UPS (V2)

1. In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें**1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

3. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

(1) Delivery require at Senior Section Engineer (Electric) Power office, Near Running Room, Vatva Railway Yard, Vinzol railway crossing, Vatva Ahmedabad-382445. Gujarat. (Contact No: 9724093376)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---