

Bid Document/ बिड दस्तावेज़

| Bid Details/बिड विवरण | |
|---|--|
| Bid End Date/Time/बिड बंद होने की तारीख/समय | 12-06-2024 19:00:00 |
| Bid Opening Date/Time/बिड खुलने की तारीख/समय | 12-06-2024 19:30:00 |
| Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से) | 180 (Days) |
| Ministry/State Name/मंत्रालय/राज्य का नाम | Ministry Of Defence |
| Department Name/विभाग का नाम | Department Of Defence Research & Development |
| Organisation Name/संगठन का नाम | Office Of Dg (mss) |
| Office Name/कार्यालय का नाम | ***** |
| Total Quantity/कुल मात्रा | 10 |
| Item Category/मद केटेगरी | Online UPS (V2) (Q2) |
| MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है | Yes |
| Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover/ टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है | Yes |
| Document required from seller/विक्रेता से मांगे गए दस्तावेज़ | OEM Authorization Certificate, Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया | Yes |
| RA Qualification Rule | H1-Highest Priced Bid Elimination |
| Type of Bid/बिड का प्रकार | Two Packet Bid |
| Primary product category | Online UPS (V2) |
| Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय | 4 Days |
| Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No |

| Bid Details/बिड विवरण | |
|------------------------------------|-----------------------------|
| Evaluation Method/मूल्यांकन पद्धति | Total value wise evaluation |

EMD Detail/ईएमडी विवरण

| | |
|-------------------|----|
| Required/आवश्यकता | No |
|-------------------|----|

ePBG Detail/ईपीबीजी विवरण

| | |
|--|---------------------|
| Advisory Bank/एडवाइजरी बैंक | State Bank of India |
| ePBG Percentage(%) / ईपीबीजी प्रतिशत (%) | 5.00 |
| Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने). | 26 |

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

Director ITR
Integrated Test Range Chandipur, Department of Defence Research & Development, Office of DG (MSS), Ministry of Defence
(Director)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

| | |
|--|-----|
| MII Purchase Preference/एमआईआई खरीद वरीयता | Yes |
|--|-----|

MSE Purchase Preference/एमएसई खरीद वरीयता

| | |
|---|-----|
| MSE Purchase Preference/एमएसई खरीद वरीयता | Yes |
|---|-----|

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and

"Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.

3. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

4. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

5. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Online UPS (V2) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

| | |
|--------------|-----|
| Bis Required | Yes |
|--------------|-----|

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|---------------|------------------------------------|--|
| Generic | Rating in KVA | 160 KVA |
| | Switching Technology | IGBT-PWM |

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|--------------------------|--|---|
| | Input Voltage | AC Three phase 300 V - 450V sinewave 50Hz |
| | Output Voltage | AC 3 Phase 400V +/-1% with alternative user settable setting of 380V +/-1% 50 Hz |
| | Warranty for UPS (Years) | 2, 3, 4, 5 Or higher |
| | Battery/Backup Bank | With Battery |
| | Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021) | |
| | Type of Battery (hint: NA in case Battery not provided) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest |
| | Backup time (Minutes) (hint: NA in case battery not provided) | 15 Minutes |
| | Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided | 2, 3 Or higher |
| Performance / Functional | Inbuilt isolation transformer | With, Without |
| | Overall Efficiency (%) | >=90% with Inbuilt isolation transformer |
| | Overload limit | 20% Overload for minimum 10 minute, 50% Overload for minimum 1 minute |
| Accessories | Accessories | Cabling 6 meters (input upto 3m and output upto 3m), Rack for Batteries |
| Design / Construction | Type of Design / Construction | Floor Standing |

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

| S.No./क्र. सं. | Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी | Address/पता | Quantity/मात्रा | Delivery Days/डिलीवरी के दिन |
|----------------|---|---------------|-----------------|------------------------------|
| 1 | ***** | *****BALESWAR | 2 | 180 |

Online UPS (V2) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|--------------------------|---|---|
| Generic | Rating in KVA | 60.0 KVA |
| | Switching Technology | IGBT-PWM |
| | Input Voltage | AC Three phase 300 V - 450V sinewave 50Hz |
| | Output Voltage | AC 3 phase 415V having a variable setting the range starting from 380 volt - variable upto to 415 volt. |
| | Warranty for UPS (Years) | 1, 2, 3, 4, 5 Or higher |
| Battery/Backup Bank | Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021) | With Battery |
| | Type of Battery (hint: NA in case Battery not provided) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest |
| | Backup time (Minutes) (hint: NA in case battery not provided) | 15 Minutes |
| | Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided | 2, 3 Or higher |
| Performance / Functional | Inbuilt isolation transformer | With, Without |
| | Overall Efficiency (%) | >/=90% with Inbuilt isolation transformer |
| | Overload limit | 20% Overload for minimum 10 minute, 50% Overload for minimum 1 minute |

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|-----------------------|--------------------------------------|--|
| Accessories | Accessories | Rack for Batteries, Cabling 6 meters (input upto 3m and output upto 3m), Paralleling kit (Hot Standby Configuration), Paralleling kit for synchronizing (Parallel Redundant Load Sharing Configuration), SNMP Card (with Suitable Software) for communication, The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc, NA |
| Design / Construction | Type of Design / Construction | Floor Standing |

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

| S.No./क्र. सं. | Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी | Address/पता | Quantity/मात्रा | Delivery Days/डिलीवरी के दिन |
|----------------|---|---------------|-----------------|------------------------------|
| 1 | ***** | *****BALESWAR | 2 | 180 |

Online UPS (V2) (4 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|---------------|------------------------------------|--|
| Generic | Rating in KVA | 40.0 KVA |
| | Switching Technology | IGBT-PWM |
| | Input Voltage | AC Three phase 300 V - 450V sinewave 50Hz |
| | Output Voltage | AC 3 Phase 400V +/-1% with alternative user settable setting of 380V +/-1% 50 Hz |
| | Warranty for UPS (Years) | 2, 3, 4, 5 Or higher |

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|--------------------------|--|---|
| Battery/Backup Bank | Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021) | With Battery |
| | Type of Battery (hint: NA in case Battery not provided) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest |
| | Backup time (Minutes) (hint: NA in case battery not provided) | 15 Minutes |
| | Warranty for battery (Years) by Battery Manufacaturer/Brand hint: NA in case battery not provided | 2, 3 Or higher |
| Performance / Functional | Inbuilt isolation transformer | With, Without |
| | Overall Efficiency (%) | >/=90% with Inbuilt isolation transformer |
| | Overload limit | 20% Overload for minimum 5 minute, 50% Overload for minimum 1 minute, 50% Overload for minimum 3 seconds |
| Accessories | Accessories | Rack for Batteries, Cabling 6 meters (input upto 3m and output upto 3m), The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc |
| Design / Construction | Type of Design / Construction | Floor Standing |

Additional Specification Parameters - Online UPS (V2) (4 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|---|
| Backup Time | 30 minutes with tubular lead acid battery |

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

| S.No./क्र. सं. | Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी | Address/पता | Quantity/मात्रा | Delivery Days/डिलीवरी के दिन |
|----------------|---|---------------|-----------------|------------------------------|
| 1 | ***** | *****BALESWAR | 4 | 180 |

Online UPS (V2) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|--------------------------|---|---|
| Generic | Rating in KVA | 30.0 KVA |
| | Switching Technology | IGBT-PWM |
| | Input Voltage | AC Three phase 300 V - 450V sinewave 50Hz |
| | Output Voltage | AC 3 Phase 400V +/-1% with alternative user settable setting of 380V +/-1% 50 Hz |
| | Warranty for UPS (Years) | 2, 3, 4, 5 Or higher |
| Battery/Backup Bank | Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021) | With Battery |
| | Type of Battery (hint: NA in case Battery not provided) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest |
| | Backup time (Minutes) (hint: NA in case battery not provided) | 15 Minutes |
| | Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided | 2, 3 Or higher |
| Performance / Functional | Inbuilt isolation transformer | With, Without |
| | Overall Efficiency (%) | >/=90% & <94% without Inbuilt isolation transformer |

| Specification | Specification Name/विशिष्टि का नाम | Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य |
|-----------------------|--------------------------------------|--|
| | Overload limit | 20% Overload for minimum 5 minute, 50% Overload for minimum 1 minute, 50% Overload for minimum 3 seconds |
| Accessories | Accessories | Rack for Batteries, Cabling 6 meters (input upto 3m and output upto 3m), The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc |
| Design / Construction | Type of Design / Construction | Floor Standing |

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

| S.No./क्र. सं. | Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी | Address/पता | Quantity/मात्रा | Delivery Days/डिलीवरी के दिन |
|----------------|---|---------------|-----------------|------------------------------|
| 1 | ***** | *****BALESWAR | 2 | 180 |

Buyer added Bid Specific Additional Scope of Work

| S.No.क्र.सं. | Document Title | Description | Applicable/रिवर्स प्रभार के अनुसार जोएसटी i.r.o. Items |
|--------------|---------------------------------------|--|--|
| 1 | Scope of Work View | Item to be supplied as per scope of work | Online UPS (V2)(2) |
| 2 | Scope of Work View | Item to be supplied as per scope of work | Online UPS (V2)(2) |
| 3 | Scope of Work View | Item to be supplied as per scope of work | Online UPS (V2)(4) |
| 4 | Scope of Work View | Item to be supplied as per scope of work | Online UPS (V2)(2) |

| S.No.क्र.सं. | Document Title | Description | Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items |
|--------------|--|--|--|
| 5 | List of deliverables View | Items to be supplied as per list of deliverables | Online UPS (V2)(2) |
| 6 | Details of Supply View | Item to supplied as per attached locations | Online UPS (V2)(2) |
| 7 | Price bid format View | Financial documents to be attached as per the price bid format | Online UPS (V2)(2) |

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

Special terms and conditions-Version:1 effective from 06-07-2022 for category Online UPS (V2)

1. In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

2. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.
- d. Copy of EFT Mandate duly certified by Bank.

3. Generic

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained

mismatch of technical parameters, the bid is liable for rejection.

4. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

5. **Generic**

1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior written consent of buyer.
3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

6. **Generic**

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.
- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

7. **Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

8. **OEM**

IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

9. **Purchase Preference (Centre)**

Purchase Preference linked with Local Content (PP-LC) Policy:

The bid clause regarding "Preference to Make In India products" stands modified in this bid and shall be governed by the PPLC Policy No. FP-20013/2/2017-FP-PNG dated 17.11.2020 issued by MoP&NG as amended up to date. Accordingly, bidders with Local Content less than or equal to 20% will be treated as "Non Local Supplier". The prescribed LC shall be applicable on the date of Bid opening. Sanctions on the bidders for false / wrong declaration or not fulfilling the Local Content requirement shall be as per the PPLC policy. Further following additional provisions are added in the certification and verification of local content provision of the Preference to Make in India clause:

- i. In case of foreign bidder, certificate from the statutory auditor or cost auditor of their own office or subsidiary in India giving the percentage of local content is also acceptable. In case office or subsidiary in India does not exist or Indian office/subsidiary is not required to appoint statutory auditor or cost auditor, certificate from practicing cost accountant or practicing chartered accountant giving the percentage of local content is also acceptable.
- ii. Along with Each Invoice: The local content certificate (issued by statutory auditor on behalf of procuring company) shall be submitted along with each invoice raised. However, the % of local

content may vary with each invoice while maintaining the overall % of local content for the total work/purchase of the pro-rata local content requirement. In case, it is not satisfied cumulatively in the invoices raised up to that stage, the supplier shall indicate how the local content requirement would be met in the subsequent stages.

- iii. The bidder shall submit an undertaking from the authorized signatory of bidder having the Power of Attorney along with the bid stating the bidder meets the mandatory minimum LC requirement and such undertaking shall become a part of the contract.

10. **Service & Support**

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

11. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

12. **Service & Support**

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

13. **Warranty**

Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 5 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

14. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of

Director ITR

A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.

15. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and

resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action

in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---