

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	03-06-2024 12:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	03-06-2024 12:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	180 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Odisha
Department Name/विभाग का नाम	Skill Development And Technical Education Department. Odisha
Organisation Name/संगठन का नाम	N/a
Office Name/कार्यालय का नाम	Directorate Of Technical Education And Training , Odisha , Cuttack
Total Quantity/कुल मात्रा	2
Item Category/मद केटेगरी	Power Generator - DG Set (up to 900 KVA) (Q2)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	8 Lakh (s)
OEM Average Turnover (Last 3 Years)/मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)	60 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है	Yes
Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover/ टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है	Yes

Bid Details/बिड विवरण	
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance/विगत प्रदर्शन	80 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Power Generator - DG Set (up to 900 KVA)
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	32000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	14

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन

जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

PRINCIPAL

Village-Bhalipur, At/Po-Rua B.O, Chandrapur, Dist-PURI, ODISHA-752012

(Principal Government Iti Rua, Puri)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	No
---	----

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	No
--	----

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
3. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
5. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

8. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Power Generator - DG Set (up To 900 KVA) (1 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	62.5
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase
ENGINE	Rated Engine Power (kWm)	100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency, 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher
	Type of Engine cooling	Liquid Cooled
	Type of governer	Electronic Or higher
	Number of cylinders (nos)	4
	Rated RPM of Engine (RPM)	1500

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Fuel	High Speed Diesel (HSD)
	Starting voltage (volt)	12
GOVERNING CLASS	"Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) "	15
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	5.0 (second)
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1.5
ALTERNATOR	Alternator Voltage Rating	415.0 (Volt)
	Efficiency at rated Power factor at 75% of full Load	93.7 - 100.0 Or higher (percent)
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Voltage Regulation Grade	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
CONTROL PANEL	Control Panel	AMF Control Panel
	IP Rating of Control Panel	IP 53, IP 54, IP 55 Or higher
	Display meters in the control panel (with appropriate rating and accuracy class) - inclusive in the scope of supply	Voltmeter, Ammeter, Frequency meter, Power Factor meter, Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger
	Displayed parameters/Features	Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Powerfactor, Frequency, Fuel level, Event log, Control supply Voltage
	Indicators	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
ACOUSTIC ENCLOSURE	Sheet Thickness(mm)	1.6, 1.8, 2 Or higher
	Thickness of insulation	40.0 - 120.0 Or higher (millimeter)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Density of insulation (kg/cubic m)	28.0 - 100.0 Or higher
	Noise level at 1 meter (dB)	75
Fuel Tank	Fuel Tank Sheet Material Thickness(mm)	2, 3 Or higher
BATTERY	No of batteries	1
SALIENT FEATURES	Salient Features of Power Generator	Glass window on Accoustic Enclosure in front of the Control Panel, Emergency Stop outside the Accoustic Enclosure
TRAILER	Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay load of the Trailer	0, 500, 1000, 2000 Or higher (kilogram)
SCOPE OF INSTALLATION	Installation	with installation - inclusive in the scope of supply Or higher
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICES	Warranty on Complete power genertor/DG Set	12, 24, 36 Or higher (month)
	Warranty in running hours	5000.0 - 5000.0 Or higher (hour)
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*	2
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB
	Test report Available for (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications

Additional Specification Parameters - Power Generator - DG Set (up To 900 KVA) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Single Source Power Assurance	The engine, Alternator, controller, turbo, and battery must be manufactured by the same brand. The bidder must provide documentary proof regarding the same while participating in the bid and the weblinks for verification by the technical team on web.
FUEL TANK	A fuel tank of 150 Liters and the same shall be integrated into the base of the Genset complete with drain valve, air vent, and outlet connection. The specification for fuel tank except this is not valid.
Site Visit	Yes
TEST REPORT	Engine must be Designed & Tested for operation @ 50 Deg Centigrade ambient temperature. Letter from principal manufacturer to be submitted by the bidder.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arun Kumar Murmu	752012,Village-Bhalipur,At/Po-Rua B.O, Chandrapur, Dist-PURI,	1	60

Power Generator - DG Set (up To 900 KVA) (1 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	7.5
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
ENGINE	Rated Engine Power (kWm)	110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxilary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficeience Or higher
	Type of Engine cooling	Liquid Cooled
	Type of governer	Mechanical, Electronic Or higher
	Number of cylinders (nos)	2
	Rated RPM of Engine (RPM)	1500
	Fuel	High Speed Diesel (HSD)
	Starting voltage (volt)	12
GOVERNING CLASS	"Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) "	15.0 (second)
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent)	5
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) "	4
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	5.0 (second)
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1.5
ALTERNATOR	Alternator Voltage Rating	415.0 (Volt)
	Efficiency at rated Power factor at 75% of full Load	80.2 - 100.0 Or higher (percent)
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Voltage Regulation Grade	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
CONTROL PANEL	Control Panel	AMF Control Panel

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Display meters in the control panel (with appropriate rating and accuracy class) - inclusive in the scope of supply	Voltmeter, Ammeter, Frequency meter, Power Factor meter
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger
	Displayed parameters/Features	Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Powerfactor, Frequency, Event log, Control supply Voltage
ACOUSTIC ENCLOSURE	Sheet Thickness(mm)	1.6, 1.8, 2 Or higher
Fuel Tank	Number of Fuel tank	1
	Fuel Tank Sheet Material Thickness(mm)	2, 3 Or higher
BATTERY	Battery capacity (Ah)	65, 32
	No of batteries	1
TRAILER	Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay load of the Trailer	0, 500, 1000, 2000 Or higher (kilogram)
SCOPE OF INSTALLATION	Installation	with installation - inclusive in the scope of supply Or higher
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICE S	Warranty on Complete power genertor/DG Set	24, 36 Or higher (month)
	Warranty in running hours	5000.0 - 5000.0 Or higher (hour)
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*	3

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
TEST REPORTS	Test report Available for (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications

Additional Specification Parameters - Power Generator - DG Set (up To 900 KVA) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Single Source Power Assurance	The engine, Alternator, controller, turbo, and battery must be manufactured by the same brand. The bidder must provide documentary proof regarding the same while participating in the bid and the weblinks for verification by the technical team on web.
Site Visit	Yes
Attendance of complaint	Attendance of complaint must be within 4 hours of complaint login. Letter from principal manufacturer to be submitted by the bidder
TEST REPORT	Engine must be Designed & Tested for operation @ 50 Deg Centigrade ambient temperature. Letter from principal manufacturer to be submitted by the bidder.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arun Kumar Murmu	752012,Village-Bhalipur,At/Po-Rua B.O, Chandrapur, Dist-PURI,	1	60

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up

to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. **Generic**

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

3. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

PRINCIPAL GOVT ITI RUA
Village-Bhalipur
At/Po-Rua
B.O, Chandrapur
Dist-PURI ODISHA-752012

4. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

5. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

6. **Generic**

Manufacturer Authorization:Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

7. **Generic**

OPTIONAL SITE VISIT:

1. The Bidder is advised to visit and examine the installation site and its surroundings and obtain for itself on its own responsibility all information that may be necessary for preparing the Bid. The costs of visiting the site shall be borne by the Bidder.

BIDDERS NEED TO VISIT SITE AND VERIFY THE INSTALLATION COMPONENT & SUBMIT COMPLIANCE. (MANDATORY)

2. The Bidder representative shall be allowed entry upon consignee premises for such visits, only upon the express conditions that the Bidder will release and indemnify the Buyer and Consignee against all liabilities arising out of such visit including death or injury, loss or damage to property, and any other loss, damage, costs, and expenses incurred as a result of such visit.

3. The Bidder shall not be entitled to hold any claim against Buyer for noncompliance due to lack of any kind of pre-requisite information as it is the sole responsibility of the Bidder to obtain all the necessary information with regard to site, surrounding, working conditions, weather etc. on its own before submission of the bid.

8. **Generic**

Scope of supply includes Training: Number of employees to be trained

, Place for Training
GOVT ITI RUA
and Duration of training
1
days.

9. Generic

The successful bidder has to supply all essential accessories required for the successful installation and commissioning of the goods supplied. Besides standard accessories as per normal industry practice, following accessories must be part of supply and cost should be included in bid price:

ALL INSTALLATION COMPONET AND ACCESSORIES

.

10. Generic

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.
- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

11. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

12. Turnover

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

13. Turnover

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

14. Service & Support

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

15. Service & Support

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

16. Service & Support

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

17. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

18. Certificates

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

19. Certificates

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

20. Certificates

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

21. Certificates

To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid):

Type approval certificate for the offered engine and alternator should be provided.

22. Warranty

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

23. Warranty

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

24. Forms of EMD and PBG

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

PRINCIPAL GOVT ITI RUA
payable at
PURI

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

25. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of

PRINCIPAL GOVT ITI RUA

A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.

26. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. Bidders to submit Bid Specific Authorization with OEM contact details (Name, Email ID & Phone Number etc.) of the signatory with digital signature, subject to revalidation from Local OEM representation /Local Manager.

2. Bidder must have a Functional Office in the State of Consignee's Location. Document proof of this must be uploaded by Bidder.

3. Engine must be Designed & Tested for operation @ 50 Deg Centigrade ambient temperature. Letter from principal manufacturer to be submitted by the bidder.

4. Acoustic Enclosure: 11 tank pre treatment process and UV resistant powder coating of all parts to withstand extreme. Acoustic Enclosure shall be made of Pre-treated and powder coated CRCA sheet. The sheet shall be Pre- treated and powder Coated with weather Proof paint. The Acoustic Enclosure shall be vermin proof.

5. Warranty: Two major components of DG set like, Engine & Alternator must be warranted for a period of 24 months from the date of dispatch or 5000 hrs. of operations, whichever happens earlier. Defects arising due to faulty installation, and/or commissioning, misuse, faulty storage and/or handling, improper maintenance, normal wear-tear and damages caused due to accidents are specifically excluded. Warranty of 5 years or 5000 hrs., whichever is earlier, is to be provided on five major components of engine i.e. cylinder head, crank shaft, cam shaft, cylinder block and connecting rod. Acoustic Enclosure, Panel and Accessories should stand warranty for 12 months from the date of delivery.

6. Block Loading capacity of the engine should be highest in the industry. Letter from principal manufacturer to be submitted by the bidder.

7. ISO Certification of OEM 9001:2015, must be uploaded by the Bidder.

8. GEM Bid specific compliance should be submitted on OEMs letterhead with seal and signature.

9. Declaration with document proof for support & service centre in Odisha is to be submitted by Bidder from OEM in their Letter Head.

10. Type approval certificate for the offered engine and alternator should be provided.

11. Conformity of Production (COP) certificate for the offered DG set should be provided.

12. The detailed specification (data sheet) of the product should be available in the official website of the OEM / Technical Committee to cross check the product while evaluating the technical bid.

13. The OEM and Engine manufacturer should have its own dedicated sales & Service centre in Odisha. Proper document to be uploaded in bid.

14. Attendance of complaint must be within 4 hours of complaint login. Letter from principal manu

facturer to be submitted by the bidder.

15. Drawing & Layout to be submitted in bid for the offered DG set.

16. Bidders must have to submit a latest affidavit in Non-Judicial stamp paper with appropriate value of Rs.20/- after the date of publication of this BID which is to be uploaded by the bidder that his/ her firm has not been blacklisted by any PSUs/ Central Govt. / State Govt. failing which the bid will be summarily rejected.

17. Bidder's GSTIN registration copy, PAN must be submitted.

18. Bidder must submit last 3-year IT Return for Assessment Year (2021-22, 2022-23, 2023-24) and Financial Statement of that financial year. - Submitted.

19. Bidder must submit latest GST Return for the last three month and the bidder must upload it at the time of participating Bid.

20. OEM Last 3 Years CA Certified Turnover Certificate must be uploaded with valid UDIN.

21. THE PRINCIPAL Govt ITI RUA PURI HAS RIGHT TO ACCEPT/REJECT THE BID WITHOUT ASSIGNING ANY REASONS THEREOF.

22. ALL THE LEGAL MATTER IS SUBJECT TO PURI JURISDICTION (ODISHA).

23. Seller should provide all the documents mandatory mentioned in the bid ATC.

24. Bidder should comply all ATC terms and Conditions and specifications else disqualified.

25. All the items quoted price should be inclusive of installation, supply and commission.

26. Scope of supply undertaking to be given for all the items.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.

11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action

in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---