

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	03-06-2024 15:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	03-06-2024 15:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	80 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Coal
Department Name/विभाग का नाम	Coal India Limited
Organisation Name/संगठन का नाम	South Eastern Coalfields Limited
Office Name/कार्यालय का नाम	Secl Bilaspur Chhattisgarh
Total Quantity/कुल मात्रा	46
Item Category/मद केटेगरी	Metal Oxide Lightning Arresters Without Gaps as per IS 3070 (Part 3) (Q3)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	1 Year (s)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/	Yes
Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/	Yes
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,OEM Authorization Certificate,Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Metal Oxide Lightning Arresters Without Gaps as per IS 3070 (Part 3)
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	7 Days

Bid Details/बिड विवरण	
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Item wise evaluation/

EMD Detail/ईएमडी विवरण

Required/आवश्यकता	No
-------------------	----

ePBG Detail/ईपीबीजी विवरण

Required/आवश्यकता	No
-------------------	----

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	No
--	----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
4. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned

Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. 5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

Evaluation Schedules	Item/Category	Quantity
Schedule 1	Metal Oxide Lightning Arresters Without Gaps As Per Is 3070 (part 3)	14
Schedule 2	Metal Oxide Lightning Arresters Without Gaps As Per Is 3070 (part 3)	30
Schedule 3	Metal Oxide Lightning Arresters Without Gaps As Per Is 3070 (part 3)	2

Metal Oxide Lightning Arresters Without Gaps As Per IS 3070 (Part 3) (14 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	BIS Marked	No
STANDARD RATINGS	Rated Voltage (in KV)	36
	Nominal discharge current (in KA)	10
	Highest system Voltage (in KV rms)	36
	Line discharge class	3
PRESSURE RELIEF CLASS	Pressure relief device fitted	Yes
	Minimum Prospective Symmetrical fault current (in KA rms), Pressure relief class	40
INSULATION WITHSTAND	Power Frequency test voltage (in KV rms)	28

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Lightning impulse test voltage (in KV peak)	75
	Switching impulse test voltage (in KV Peak) (hint: refer Cl.6.2.7 of IS:3070 (Part 3):1993)	1050
CONSTRUCTION	Installation class	Outdoor
	Creepage distance, Minimum (in mm)	900, 25 mm per KV
	Arrestors shall be	Hermetically sealed units, self-supporting construction
	Suitable for mounting on	Tubular type supporting structure
	Fitting accessories	Yes. Included

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Ayush Sohane	484116, Regional Store, SECL- Sohagpur Area, Post- Amlai, Distt. Anuppur, Pin-484116	14	30

Metal Oxide Lightning Arresters Without Gaps As Per IS 3070 (Part 3) (30 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	BIS Marked	No
STANDARD RATINGS	Rated Voltage (in KV)	3
	Nominal discharge current (in KA)	10

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Highest system Voltage (in KV rms)	3.6
	Line discharge class	1
PRESSURE RELIEF CLASS	Pressure relief device fitted	Yes
	Minimum Prospective Symmetrical fault current (in KA rms), Pressure relief class	5
INSULATION WITHSTAND	Power Frequency test voltage (in KV rms)	10
	Lightning impulse test voltage (in KV peak)	40
	Switching impulse test voltage (in KV Peak) (hint: refer Cl.6.2.7 of IS:3070 (Part 3):1993)	NA
CONSTRUCTION	Installation class	Outdoor
	Creepage distance, Minimum (in mm)	900, 25 mm per KV
	Arrestors shall be	Hermetically sealed units, self-supporting construction
	Suitable for mounting on	Lattice
	Fitting accessories	Yes. Included

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Ayush Sohane	484116, Regional Store, SECL- Sohagpur Area, Post- Amlai, Distt. Anuppur, Pin-484116	30	30

Metal Oxide Lightning Arresters Without Gaps As Per IS 3070 (Part 3) (2 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	BIS Marked	No
STANDARD RATINGS	Rated Voltage (in KV)	6
	Nominal discharge current (in KA)	10
	Highest system Voltage (in KV rms)	12
	Line discharge class	1
PRESSURE RELIEF CLASS	Pressure relief device fitted	Yes
	Minimum Prospective Symmetrical fault current (in KA rms), Pressure relief class	10
INSULATION WITHSTAND	Power Frequency test voltage (in KV rms)	10
	Lightning impulse test voltage (in KV peak)	10
	Switching impulse test voltage (in KV Peak) (hint: refer Cl.6.2.7 of IS:3070 (Part 3):1993)	NA
CONSTRUCTION	Installation class	Outdoor
	Creepage distance, Minimum (in mm)	900, 25 mm per KV
	Arrestors shall be	Hermetically sealed units, self-supporting construction
	Suitable for mounting on	Lattice
	Fitting accessories	Yes. Included

Consignees/Reporting Officer/परेषितो/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Ayush Sohane	484116,Regional Store, SECL-Sohagpur Area, Post- Amlai, Distt. Anuppur, Pin-484116	2	30

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. Generic

Manufacturer Authorization:Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

3. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

4. Warranty

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

5. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

Item no. 1 : Lightning Arrestor suitable for 33 KV with Hardware(Non Linear type) .

Type Test Report from Government approved Lab / NABL as per relevant IS must be uploaded along with the Bid.

Item no. 2 : Lightning Arrestor suitable for 3.3 KV with Hardware(Non Linear type) .

Type Test Report from Government approved Lab / NABL as per relevant IS must be uploaded along with the Bid.

Item no. 3 : Lightning Arrestor suitable for 6.6 KV with Hardware(Non Linear type) .

Type Test Report from Government approved Lab / NABL as per relevant IS must be uploaded along with the Bid.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---